SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Kwik-Wall

4650 Industrial Avenue, Springfield, Illinois 62703, United States

For the following product(s):

Architectural Walls:

2000 Series, 3000 Series, Luminous Series

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-105 v4.2-2023 Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January 2017) for the school Classroom¹ and private office² scenarios.

¹Modeled with 18.76 m² wall coverage

²Modeled with 10.03 m² wall coverage

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-IAQ-11061

Valid from: October 30, 2025 to October 29, 2026







Herry